



\* 3 1/2" max, 2 1/2" min.

## TYPICAL SECTION

### NOTES:

1. Rolled curb and gutter shall not be used :
  - A. On streets in commercial and industrial zoned areas.
  - B. On streets with longitudinal (lengthwise) grades in excess of 10 percent.
  - C. On any arterial.
  - D. Without prior approval of the Engineer.
2. Changes from standard curb and gutter to rolled curb require a smooth transition of 30 inches minimum length.
3. Joint spacing, base rock, and materials shall be as for standard curb and gutter.
4. Control joints with tooled edges shall be cut  $\frac{1}{4}$  to  $\frac{1}{3}$  of the section depth at 10-foot intervals, or as directed by the Engineer. Curb joints shall match street joints when adjacent to concrete pavement.
5. All exposed edges shall be tooled to a 1/2-inch radius (min).
6. Catch basins in rolled curb and gutter shall be similar in material and dimensions to standard frames and grates, but with no hood, and with a cross section approximating that of the rolled curb and gutter. Use East Jordan Iron Works 7711 Series, D&L I-4444-01 or approved equal .
7. Standard curb ramps are required in rolled curb.
8. Do not use expansion joints.
9. Construction stakes shall establish lip of gutter for both horizontal and vertical control.
10. Sidewalk adjacent to rolled curb requires a 5-foot-wide landscape strip between the back of curb and the sidewalk; 3-foot minimum on culdesac streets.

# ROLLED CURB AND GUTTER

PAGE NO:

7